



**DEPARTMENT OF SOCIAL WORK**  
**UNIVERSITY OF KASHMIR**  
HAZRATBAL SRINAGAR KASHMIR 190006

KU/MSW/719/2017  
Dt: 21/09/2017

No:F(Stabilizer-MSW)KU/17  
Dated: 21/09/2017

Supply and Installation of Servo Voltage Stabilizer

Quotations are invited from reputed manufacturers/firms/agencies or their authorized distributors for, supply and installation of one 10KVA Servo voltage stabilizer. The last date for receiving the quotations by post/hand is 26/09/2017 latest by 4:30 PM to be opened at 02:00 PM on 28/09/2017. Interested parties can download the detailed specification of the stabilizer from the website of the Department ([socialwork.uok.edu.in](http://socialwork.uok.edu.in))

Dr. Shazia Manzoor  
Coordinator

Copy to:-

1. Public Relations Officer with the request to publish the Notice in local daily (Greater Kashmir)
2. File

### TECHNICAL SPECIFICATION 10 KVA SERVO STABLIZER.

Capacity/Rating	10 KVA
General	Single phase servo voltage stabilizer, suitable for indoor use, withstand ambient temp up to 55 degree C, oil cooled immersed in tank, control circuit for correction, suitable for balanced/unbalanced supply and load
Winding	Copper Wound
Input Voltage	90-270V
Input Frequency	50HZ +/- 5%
Output Voltage	240V +/- 1%
First Fill Oil	Included
Cooling	ONAN
Mounting	Floor type
Indication	Mains ON indication on front panel.